

From: [REDACTED]
To: [Filippini, Mark](#); [REDACTED]; [Fleming, Sheila](#)
Cc: [REDACTED]
Subject: RE: Park Place Water Sampling QAPP
Date: Thursday, May 15, 2014 4:27:55 PM
Attachments: [mls-Park Place Drinking Water QAPP Draft 5 14 2014.docx](#)

Mark,

Thanks for sharing this.

A couple of comments could change your plan:

- Specify a sample volume of 250 ml
- & 8-hours since last use for first draw.

Other comments are editorial, but I strongly suggest you commit up front to timely sharing of results with all staff; not just Senior Management. Anything less, will decrease confidence.

It's all in comments & tracked changes(attached):

Regards,

(b) (6)

(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)

(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)

(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)

(b) (6)(b) (6)

(b) (6)(b) (6)(b) (6)(b) (6)

U.S. Environmental Protection Agency, Region 10

(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)

1200 Sixth Avenue, Suite 900

Mail Stop: OEA-095

Seattle, Washington 98101-3140

Tele 206/553-(b) (6)

Facs 206/553-0119

(b) (6)(b) (6) @epa.gov

From: Filippini, Mark

Sent: Thursday, May 15, 2014 11:56 AM

To: (b) (6)(b) (6)(b) (6)(b) (6)(b) (6) ; Fleming, Sheila

Subject: RE: Park Place Water Sampling QAPP

(b)

We are looking for input. Sean suggested this morning that you would be a good person to look over our QAPP.

The Phase 1 approach is to sample each of the water fountains, kitchen sinks, and ice from the refrigerators on Floors 7 to 13 and 18. We will be analyzing for Lead and Copper.

Here is the draft that Don Matheny put together. Let me know what you think.

Thanks

Mark

Mark Filippini, Manager
Environmental Services Unit
R10 Safety & Health Management Representative
USEPA Region 10, Seattle
(206) 553-6327
filippini.mark@epa.gov

From: (b) (6)(b) (6)

Sent: Thursday, May 15, 2014 11:52 AM

To: (b) (6)(b) (6) ; Filippini, Mark; Fleming, Sheila

Subject: RE: fyi, suggested you take a look at the bldg tapwater qapp

I'd be happy to review.

I didn't get the impression Mark was looking for input.

I could be wrong?

[illegible][illegible][illegible]

(b) (6)(b) (6)

(b) (6)(b) (6)(b) (6)(b) (6)
U.S. Environmental Protection Agency, Region 10
(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)
1200 Sixth Avenue, Suite 900
Mail Stop: OEA-095
Seattle, Washington 98101-3140
Tele 206/553- (b) (6)
Facs 206/553-0119
(b) (6)(b) (6) [@epa.gov](mailto:(b) (6)(b) (6)@epa.gov)

From: (b) (6)(b) (6)
Sent: Thursday, May 15, 2014 11:50 AM
To: (b) (6)(b) (6)
Subject: RE: fyi, suggested you take a look at the bldg tapwater qapp

I know, crazy idea, I told Mark F to get with you b/c I think lead sampling protocols are something you have more experience with than anyone else!

(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)
EPA Region 10, 1200 Sixth Ave., Suite 900
Seattle, WA 98101
206.553. (b) (6) desk
206. (b) (6) cell
(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)
(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)

(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)

From: (b) (6)(b) (6)
Sent: Thursday, May 15, 2014 11:45 AM
To: (b) (6)(b) (6)
Subject: RE: fyi, suggested you take a look at the bldg tapwater qapp

I haven't seen it.

Why would they talk to the lead risk assessor?

(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)

(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)
(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)

(b) (6)(b) (6)

(b) (6)(b) (6)(b) (6)(b) (6)
U.S. Environmental Protection Agency, Region 10

(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)
1200 Sixth Avenue, Suite 900
Mail Stop: OEA-095
Seattle, Washington 98101-3140
Tele 206/553- (b) (6)
Facs 206/553-0119
(b) (6)(b) (6) [@epa.gov](mailto:(b) (6)(b) (6)@epa.gov)

From: (b) (6)(b) (6)
Sent: Thursday, May 15, 2014 9:45 AM
To: (b) (6)(b) (6)
Subject: fyi, suggested you take a look at the bldg tapwater qapp

Worried that too many QA folks, too few experienced risk assessors look at it, and they could miss a lot of best practices stuff.

Also you might want to clear misconceptions of various contrivances of "lead free" as far as solder and fixtures...

Just since you have overseen the most tapwater sampling events I think of anyone in the region!

(

(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)
EPA Region 10, 1200 Sixth Ave., Suite 900
Seattle, WA 98101
206.553. (b) (6) desk
206. (b) (6) cell
(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)
(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)

(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)(b) (6)